

PORTABLE APPLIANCE TEST CERTIFICATE

Customer <i>Eug Thomasson</i>	Address <i>The wing</i>		Date of Test <i>28/10/12</i>	Sheet <i>1</i> of <i>2</i>
Contact Name	<i>Achnadish Haze</i>		Next Test Date	
	<i>Devaig. 10/11</i>		Engineer <i>Rebecca Butten</i>	

Make of PAT Tester <i>KewSpec</i>	Model <i>KT71</i>	Serial No. <i>W08296950</i>	Date Calibrated <i>13/04/12</i>
--------------------------------------	----------------------	--------------------------------	------------------------------------

Appliance ID No.	Description	Location	Manufacturer	Serial No.	Class	Fuse A	Earth Bond Test Current	Earth Bond Ω	Insulation M Ω	Load	Leak mA	Comments / Other Tests (01) - Replace Incorrect Fuse (02) - Reft Plug (03) - Replace Plug	Pass	Fail
001	ext lead	Double bed			1	B		0.01	720				✓	
002	lamp	"			1	B			720	0.02	0.07		✓	
003	lamp	"			1	B			720	0.01	0.07		✓	
004	hair dryer	"	Baby liss		1	B			720	8.42	0.07		✓	
005	lamp	Twin			1	B			720	0.01	0.07		✓	
006	lamp	"			1	B			720	0.01	0.07		✓	
007	ext lead	Double bed			1	B		0.02	720				✓	
008	water heater	"			1	B			720	0.01	0.08		✓	
009	lamp	"			1	B			720	0.02	0.07		✓	
010	lamp	"			1	B			720	0.04	0.07		✓	
011	hair dryer	"			1	B			720	6.74	0.07		✓	
012	lamp	Lounge			1	B			720	0.01	0.07		✓	
013	lamp	"			1	B			720	0.02	0.07		✓	
014	lamp	"			1	B			720	0.02	0.07		✓	
015	dealing station	Bush			1	B			720	0.01	0.07		✓	
016	TV	Lounge	LG		1	B			720	0.05	0.09		✓	
017	ext lead	"			1	B		0.01	720				✓	
018	Paste				1	B						✓		
019	heater	Kitchen	Jade storage		1	B		0.06	720	6.44	0.08		✓	
020	heater	"	Van Hous		1	B			720	11.66	0.08		✓	

Sheet 2 of 2	Notes
--------------	-------

ed 13/04/22

[illegible]